



Solicitation Amendment No. 1

Solicitation No. 16-3329

Solicitation Due Date: August 26, 2015 **Time:** 3:00 pm

Office of Procurement
190 N. Litchfield Road
P.O. Box 5100
Goodyear, AZ 85338
Phone: 623-882-7879



Spare Well Motors

Question: Do you have the rest of the info for Well 22 as you do on the others? Model, HP, etc.

Answer: Model: Titan II, Type: RUE, Enclosure: WPI, ID#: J05 30034369-100R-01, HP: 350, Service Factor: 1.15 HZ, Max KVR: 58.6, Efficiency: 95.0, Power Factor: 88.3

No other terms, conditions, or performance standards written or implied are changed.

Procurement Specialist: Russ Welborn, CPPB

City of Goodyear	Approved as to form
By:  8/18/15	By: 
Jacquie Behrens, CPPB	Roric Massey, City Attorney

Acknowledgement by Contractor

Contractor hereby acknowledges receipt and understanding of the above amendment. Contractor shall sign and return with their submittal.

Contractor Signature:

Date: